BACKSTOP® Diaphragm Type Thermal Expansion Tanks

AC SERIES (ASME) SUBMITTAL

Lit.# BSACSUB-810

TYPE: PRE-PRESSURIZED THERMAL EXPANSION TANKS FOR RESIDENTIAL WATER SYSTEMS MODELS: AC-101; AC-102; AC-103-S; AC-104-S; AC-105-S; & AC-106-S

Job	Arrow Rep. ——————	
Unit Tag No. ———————————————————————————————————	_ Order No	Date
Engineer	Submitted By	Date
Contractor	Approved By	Date

MATERIALS:

Shell: Carbon Steel

System Connection: Stainless Steel

Coating: Epoxy

Diaphragm: Heavy Duty Butyl Rubber Liner Material: Food Grade Polypropylene Factory Pre-set Pressure: 35 PSI

OPERATING LIMITATIONS:

Maximum Design Pressure: 150 PSI (1035 kPa) Maximum Design Temperature: 200° F (93° C)



APPLICATION:

BackStop® AC (ASME) Series Tanks are fixed diaphragm type pre-charged thermal expansion tanks. They are designed to absorb the expansion forces and control the pressure in potable water systems. The water is seperated using the heavy duty diaphragm preventing tank corrosion and waterlogging

Model No.	Volume (gal.)	Accept Volume	Height	Diameter	Sys. Conn.	Wt. (lbs.)
AC5	3.5	2.1	14"	8"	3/4"	22
AC12	5	3.1	14"	11"	3/4"	28
AC20	8	3.1	20"	15-1/2"	3/4"	34
AC30	15	10	23"	15-1/2"	3/4"	64
AC42	22	14.7	32"	15-1/2"	1"	88
AC60	26	15.5	34"	22"	1"	93
AC80	35	15.5	45"	16"	1"	109
ACI00	45	21	38"	20"	1"	148
AC125	60	21	49"	20"	1"	175
AC160	70	46.7	46"	24"	1-1/2"	259
AC180	80	52.5	49"	24"	1-1/2"	268
AC210	90	52.5	52"	24"	1-1/2"	283

SPECIFICATIONS:

Furnish and install as shown on plans a ______ gallon _____ " diameter x _____ " (high) pre-charged steel expansion tank with a fixed butyl diaphragm. The tank shall have a top NPT system connection and a .301" - 32 charging valve connection (standard tire valve) to facilitate the on-site charging of the tank to meet system requirements. The tank must be constructed and stamped in accordance with Section VIII of the ASME Boiler and Pressure Vessel Code.

Each tank shall be BackStop® model number_____or approved equal.

465 N. Berry St. Brea, CA 92821 • Tel. 800-242-7769 • www.backstop.net

SCHEDULE: